

# SPECIAL SEISMIC CERTIFICATION COMPLIANCE REPORT – 17101CR1.0

## MANUFACTURER

LS ELECTRIC CO., LTD.

LS Tower, 127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-Do, 14119, Republic of Korea

Contact: Namki Lee - +82-41-550-8585 - nlee@ls-electric.com

## PRODUCTS

H100 VFD & SP100 VFD BYPASS

This certification covers a range of the above-referenced products. See Attachment 1 for a detailed listing of the certified products, including their mounting, construction, and limitations.

## CERTIFICATION

This certification meets the requirements of the following codes (and their prior versions): 2021 International Building Code, 2022 California Building Code, and ASCE 7-16. See Attachments 1 & 2 for seismic enhancements.

This certification covers the following seismic parameters:

$I_p=1.5$ ;  $S_{DS}=2.00g$  for  $z/h=1$  (rooftop);  $S_{DS}=2.50g$  for  $z/h=0$  (at grade).

This certification is only valid for the following mounting: RIGID OR FLEXIBLE WALL MOUNTED.


The basis of this certification is shake table testing in accordance with ICC-ES AC156.

## CERTIFICATION COMPANY

MANWILL ENGINEERING LLC

Certifying Engineer: Derek Manwill, SE

California License Number: S6266



Date Signed: 07/09/2023

## ATTACHMENT 1: CERTIFIED COMPONENTS

## SPECIAL SEISMIC CERTIFICATION

**TABLE 1**

DOCUMENT NO.: 17101CR1.0

MANUFACTURER: LS ELECTRIC CO., LTD.						
PRODUCT FAMILY: H100 VFD & SP100 VFD BYPASS						
MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>H100 VFD</b>						
LSLV0008H100-2CENN	7.1	6.3	10.5	7.3	0.75kW, 200Vac, Type 1 Conduit	EXTRAP
LSLV0008H100-2CENN+FL	7.1	6.3	10.5	7.3	0.75kW, 200Vac, Type 1, Flange	EXTRAP
LSLV0008H100-2CONN	7.1	6.3	9.1	7.3	0.75kW, 200Vac, Open	EXTRAP
LSLV0008H100-2CONN+FL	7.1	6.3	9.1	7.3	0.75kW, 200Vac, Open, Flange	EXTRAP
LSLV0008H100-4CEFN	7.1	6.3	10.5	7.3	0.75kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0008H100-4CEFN+FL	7.1	6.3	10.5	7.3	0.75kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0008H100-4COFN	7.1	6.3	9.1	7.3	0.75kW, 400Vac, Open	EXTRAP
LSLV0008H100-4COFN+FL	7.1	6.3	9.1	7.3	0.75kW, 400Vac, Open, Flange	EXTRAP
LSLV0015H100-2CENN	7.1	6.3	10.5	7.3	1.5kW, 200Vac, Type 1 Conduit	EXTRAP
LSLV0015H100-2CENN+FL	7.1	6.3	10.5	7.3	1.5kW, 200Vac, Type 1, Flange	EXTRAP
LSLV0015H100-2CONN	7.1	6.3	9.1	7.3	1.5kW, 200Vac, Open	EXTRAP
LSLV0015H100-2CONN+FL	7.1	6.3	9.1	7.3	1.5kW, 200Vac, Open, Flange	EXTRAP
LSLV0015H100-4CEFN	7.1	6.3	10.5	7.3	1.5kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0015H100-4CEFN+FL	7.1	6.3	10.5	7.3	1.5kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0015H100-4COFN	7.1	6.3	9.1	7.3	1.5kW, 400Vac, Open	EXTRAP
LSLV0015H100-4COFN+FL	7.1	6.3	9.1	7.3	1.5kW, 400Vac, Open, Flange	EXTRAP
LSLV0022H100-2CENN	7.1	6.3	10.5	7.3	2.2kW, 200Vac, Type 1 Conduit	EXTRAP
LSLV0022H100-2CENN+FL	7.1	6.3	10.5	7.3	2.2kW, 200Vac, Type 1, Flange	EXTRAP
LSLV0022H100-2CONN	7.1	6.3	9.1	7.3	2.2kW, 200Vac, Open	EXTRAP
LSLV0022H100-2CONN+FL	7.1	6.3	9.1	7.3	2.2kW, 200Vac, Open, Flange	EXTRAP
LSLV0022H100-4CEFN	7.1	6.3	10.5	7.3	2.2kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0022H100-4CEFN+FL	7.1	6.3	10.5	7.3	2.2kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0022H100-4COFN	7.1	6.3	9.1	7.3	2.2kW, 400Vac, Open	EXTRAP
LSLV0022H100-4COFN+FL	7.1	6.3	9.1	7.3	2.2kW, 400Vac, Open, Flange	EXTRAP
LSLV0037H100-2CENN	7.1	6.3	10.5	7.3	3.7kW, 200Vac, Type 1 Conduit	EXTRAP
LSLV0037H100-2CENN+FL	7.1	6.3	10.5	7.3	3.7kW, 200Vac, Type 1, Flange	EXTRAP
LSLV0037H100-2CONN	7.1	6.3	9.1	7.3	3.7kW, 200Vac, Open	EXTRAP
LSLV0037H100-2CONN+FL	7.1	6.3	9.1	7.3	3.7kW, 200Vac, Open, Flange	EXTRAP
LSLV0037H100-4CEFN	7.1	6.3	10.5	7.3	3.7kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0037H100-4CEFN+FL	7.1	6.3	10.5	7.3	3.7kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0037H100-4COFN	7.1	6.3	9.1	7.3	3.7kW, 400Vac, Open	EXTRAP
LSLV0037H100-4COFN+FL	7.1	6.3	9.1	7.3	3.7kW, 400Vac, Open, Flange	EXTRAP
LSLV0055H100-2CENN	7.1	6.3	10.5	7.3	5.5kW, 200Vac, Type 1 Conduit	EXTRAP
LSLV0055H100-2CENN+FL	7.1	6.3	10.5	7.3	5.5kW, 200Vac, Type 1, Flange	EXTRAP
LSLV0055H100-2CONN	7.1	6.3	9.1	7.3	5.5kW, 200Vac, Open	EXTRAP
LSLV0055H100-2CONN+FL	7.1	6.3	9.1	7.3	5.5kW, 200Vac, Open, Flange	EXTRAP
LSLV0055H100-4CEFN	7.1	6.3	10.5	7.3	5.5kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0055H100-4CEFN+FL	7.1	6.3	10.5	7.3	5.5kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0055H100-4COFN	7.1	6.3	9.1	7.3	5.5kW, 400Vac, Open	EXTRAP
LSLV0055H100-4COFN+FL	7.1	6.3	9.1	7.3	5.5kW, 400Vac, Open, Flange	EXTRAP
LSLV0075H100-2CENN	7.1	6.3	10.5	7.3	7.5kW, 200Vac, Type 1 Conduit	EXTRAP
LSLV0075H100-2CENN+FL	7.1	6.3	10.5	7.3	7.5kW, 200Vac, Type 1, Flange	EXTRAP

**NOTES:** Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.

## ATTACHMENT 1: CERTIFIED COMPONENTS

## SPECIAL SEISMIC CERTIFICATION

**TABLE 1 (continued)**

DOCUMENT NO.: 17101CR1.0

MANUFACTURER: LS ELECTRIC CO., LTD.						
PRODUCT FAMILY: H100 VFD & SP100 VFD BYPASS						
MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>H100 VFD (continued)</b>						
LSLV0075H100-2CONN	7.1	6.3	9.1	7.3	7.5kW, 200Vac, Open	EXTRAP
LSLV0075H100-2CONN+FL	7.1	6.3	9.1	7.3	7.5kW, 200Vac, Open, Flange	EXTRAP
LSLV0075H100-4CEFNDI	7.1	6.3	10.5	7.3	7.5kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0075H100-4CEFNDI+FL	7.1	6.3	10.5	7.3	7.5kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0075H100-4COFNDI	7.1	6.3	9.1	7.3	7.5kW, 400Vac, Open	EXTRAP
LSLV0075H100-4COFNDI+FL	7.1	6.3	9.1	7.3	7.5kW, 400Vac, Open, Flange	EXTRAP
LSLV0110H100-2CENN	7.1	6.3	10.5	7.5	11kW, 200Vac, Type 1 Conduit	EXTRAP
LSLV0110H100-2CENN+FL	7.1	6.3	10.5	7.5	11kW, 200Vac, Type 1, Flange	EXTRAP
LSLV0110H100-2CONN	7.1	6.3	9.1	7.5	11kW, 200Vac, Open	EXTRAP
LSLV0110H100-2CONN+FL	7.1	6.3	9.1	7.5	11kW, 200Vac, Open, Flange	EXTRAP
LSLV0110H100-4CEFNDI	7.1	6.3	10.5	7.5	11kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0110H100-4CEFNDI+FL	7.1	6.3	10.5	7.5	11kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0110H100-4COFNDI	7.1	6.3	9.1	7.5	11kW, 400Vac, Open	EXTRAP
LSLV0110H100-4COFNDI+FL	7.1	6.3	9.1	7.5	11kW, 400Vac, Open, Flange	EXTRAP
LSLV0150H100-2CENN	8.1	7.1	12.8	10.1	15kW, 200Vac, Type 1 Conduit	EXTRAP
LSLV0150H100-2CENN+FL	8.1	7.1	12.8	10.1	15kW, 200Vac, Type 1, Flange	EXTRAP
LSLV0150H100-2CONN	8.1	7.1	11.4	10.1	15kW, 200Vac, Open	EXTRAP
LSLV0150H100-2CONN+FL	8.1	7.1	11.4	10.1	15kW, 200Vac, Open, Flange	EXTRAP
LSLV0150H100-4CEFNDI	8.1	7.1	12.8	10.1	15kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0150H100-4CEFNDI+FL	8.1	7.1	12.8	10.1	15kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0150H100-4COFNDI	8.1	7.1	11.4	10.1	15kW, 400Vac, Open	EXTRAP
LSLV0150H100-4COFNDI+FL	8.1	7.1	11.4	10.1	15kW, 400Vac, Open, Flange	EXTRAP
LSLV0185H100-4CEFNDI	8.1	7.1	12.8	10.6	18.5kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0185H100-4CEFNDI+FL	8.1	7.1	12.8	10.6	18.5kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0185H100-4COFNDI	8.1	7.1	11.4	10.6	18.5kW, 400Vac, Open	EXTRAP
LSLV0185H100-4COFNDI+FL	8.1	7.1	11.4	10.6	18.5kW, 400Vac, Open, Flange	EXTRAP
LSLV0008H100-2CENN+DI	8.1	6.3	18.8	12.0	0.75kW, 200Vac, Type 1 Disconnect	EXTRAP
LSLV0015H100-2CENN+DI	8.1	6.3	18.8	12.0	1.5kW, 200Vac, Type 1 Disconnect	EXTRAP
LSLV0022H100-2CENN+DI	8.1	6.3	18.8	12.0	2.2kW, 200Vac, Type 1 Disconnect	EXTRAP
LSLV0037H100-2CENN+DI	8.1	6.3	18.8	12.0	3.7kW, 200Vac, Type 1 Disconnect	EXTRAP
LSLV0055H100-2CENN+DI	8.1	6.3	18.8	12.0	5.5kW, 200Vac, Type 1 Disconnect	EXTRAP
LSLV0075H100-2CENN+DI	8.1	6.3	18.8	12.0	7.5kW, 200Vac, Type 1 Disconnect	EXTRAP
LSLV0110H100-2CENN+DI	8.1	6.3	18.8	12.0	11kW, 200Vac, Type 1 Disconnect	EXTRAP
LSLV0008H100-4CEFNDI	9.2	6.3	22.3	13.0	0.75kW, 400Vac, Type 1 Disconnect	EXTRAP
LSLV0015H100-4CEFNDI	9.2	6.3	22.3	13.0	1.5kW, 400Vac, Type 1 Disconnect	EXTRAP
LSLV0022H100-4CEFNDI	9.2	6.3	22.3	13.0	2.2kW, 400Vac, Type 1 Disconnect	EXTRAP
LSLV0037H100-4CEFNDI	9.2	6.3	22.3	13.0	3.7kW, 400Vac, Type 1 Disconnect	EXTRAP
LSLV0055H100-4CEFNDI	9.2	6.3	22.3	13.0	5.5kW, 400Vac, Type 1 Disconnect	EXTRAP
LSLV0075H100-4CEFNDI	9.2	6.3	22.3	13.0	7.5kW, 400Vac, Type 1 Disconnect	EXTRAP
LSLV0110H100-4CEFNDI	9.2	6.3	22.3	13.0	11kW, 400Vac, Type 1 Disconnect	EXTRAP
LSLV0150H100-2CENN+DI	9.2	7.1	23.0	15.0	15kW, 200Vac, Type 1 Disconnect	EXTRAP
LSLV0185H100-2CENN	8.8	8.7	15.1	15.7	18.5kW, 200Vac, Type 1 Conduit	EXTRAP

**NOTES:** Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.

## ATTACHMENT 1: CERTIFIED COMPONENTS

## SPECIAL SEISMIC CERTIFICATION

**TABLE 1 (continued)**

DOCUMENT NO.: 17101CR1.0

MANUFACTURER: LS ELECTRIC CO., LTD.						
PRODUCT FAMILY: H100 VFD & SP100 VFD BYPASS						
MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>H100 VFD (continued)</b>						
LSLV0185H100-2CENN+FL	8.8	8.7	15.1	15.7	18.5kW, 200Vac, Type 1, Flange	EXTRAP
LSLV0185H100-2CONN	8.8	8.7	13.8	15.7	18.5kW, 200Vac, Open	EXTRAP
LSLV0185H100-2CONN+FL	8.8	8.7	13.8	15.7	18.5kW, 200Vac, Open, Flange	EXTRAP
LSLV0185H100-4CEFN+DI	9.2	7.1	24.6	16.0	18.5kW, 400Vac, Type 1 Disconnect	EXTRAP
LSLV0220H100-4COFN	8.8	8.7	13.8	16.5	22kW, 400Vac, Open	EXTRAP
LSLV0220H100-4COFN+FL	8.8	8.7	13.8	16.5	22kW, 400Vac, Open, Flange	EXTRAP
LSLV0300H100-4COFN	8.8	8.7	13.8	16.5	30kW, 400Vac, Open	EXTRAP
LSLV0300H100-4COFN+FL	8.8	8.7	13.8	16.5	30kW, 400Vac, Open, Flange	EXTRAP
LSLV0220H100-4CEFN	8.8	8.7	15.1	17.0	22kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0220H100-4CEFN+FL	8.8	8.7	15.1	17.0	22kW, 400Vac, Type 1, Flange	EXTRAP
LSLV0300H100-4CEFN	8.8	8.7	15.1	17.0	30kW, 400Vac, Type 1 Conduit	EXTRAP
LSLV0300H100-4CEFN+FL	8.8	8.7	15.1	21.0	30kW, 400Vac, Type 1, Flange	UUT 5
LSLV0220H100-4CEFN+DI	9.2	8.7	28.3	22.0	22kW, 400Vac, Type 1 Disconnect	INTERP
LSLV0300H100-4CEFN+DI	9.2	8.7	28.3	22.0	30kW, 400Vac, Type 1 Disconnect	INTERP
LSLV0150H100-4CEFN+DI	9.2	7.1	24.6	24.0	15kW, 400Vac, Type 1 Disconnect	UUT 2
LSLV0185H100-2CENN+DI	9.2	8.7	23.0	30.0	18.5kW, 200Vac, Type 1 Disconnect	UUT 3
LSLV0370H100-4COFD+FL	11.2	10.8	17.7	57.3	37kW, 400Vac, Open, Flange	INTERP
LSLV0370H100-4COND+FL	11.2	10.8	17.7	57.3	37kW, 400Vac, Open, Flange	INTERP
LSLV0370H100-4COFD	11.2	10.8	17.7	57.3	37kW, 400Vac, Open	INTERP
LSLV0370H100-4COND	11.2	10.8	17.7	57.3	37kW, 400Vac, Open	INTERP
LSLV0370H100-4CEFD	11.2	10.8	20.5	60.0	37kW, 400Vac, Type 1 Conduit	UUT 6
LSLV0370H100-4CEND	11.2	10.8	20.5	63.0	37kW, 400Vac, Type 1 Conduit	INTERP
LSLV0370H100-4CEFD+DI	11.2	10.8	32.7	70.0	37kW, 400Vac, Type 1 Disconnect	INTERP
LSLV0370H100-4CEND+DI	11.2	10.8	32.7	70.0	37kW, 400Vac, Type 1 Disconnect	INTERP
LSLV0450H100-4COFD	11.2	12.1	20.1	75.0	45kW, 400Vac, Open	UUT 7
LSLV0450H100-4CEFD	11.2	12.1	23.6	85.0	45kW, 400Vac, Type 1 Conduit	INTERP
LSLV0450H100-4CEND	11.2	12.1	23.6	85.0	45kW, 400Vac, Type 1 Conduit	INTERP
LSLV0550H100-4CEFD	11.2	12.1	23.6	85.0	55kW, 400Vac, Type 1 Conduit	INTERP
LSLV0550H100-4CEND	11.2	12.1	23.6	85.0	55kW, 400Vac, Type 1 Conduit	INTERP
LSLV0750H100-4COND+FL	12.8	12.1	21.7	92.0	75kW, 400Vac, Open, Flange	UUT 9
LSLV0450H100-4COFD+FL	11.2	12.1	20.1	94.8	45kW, 400Vac, Open, Flange	INTERP
LSLV0450H100-4COND	11.2	12.1	20.1	94.8	45kW, 400Vac, Open	INTERP
LSLV0450H100-4COND+FL	11.2	12.1	20.1	94.8	45kW, 400Vac, Open, Flange	INTERP
LSLV0550H100-4COFD	11.2	12.1	20.1	94.8	55kW, 400Vac, Open	INTERP
LSLV0550H100-4COFD+FL	11.2	12.1	20.1	94.8	55kW, 400Vac, Open, Flange	INTERP
LSLV0550H100-4COND	11.2	12.1	20.1	94.8	55kW, 400Vac, Open	INTERP
LSLV0550H100-4COND+FL	11.2	12.1	20.1	94.8	55kW, 400Vac, Open, Flange	INTERP
LSLV0750H100-4COND	12.8	12.1	21.7	94.8	75kW, 400Vac, Open	INTERP
LSLV0900H100-4COND	12.8	12.1	21.7	94.8	90kW, 400Vac, Open	INTERP
LSLV0900H100-4COND+FL	12.8	12.1	21.7	94.8	90kW, 400Vac, Open, Flange	INTERP
LSLV0450H100-4CEFD+DI	11.2	12.1	35.9	95.0	45kW, 400Vac, Type 1 Disconnect	INTERP
LSLV0450H100-4CEND+DI	11.2	12.1	35.9	95.0	45kW, 400Vac, Type 1 Disconnect	INTERP

**NOTES:** Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.

## ATTACHMENT 1: CERTIFIED COMPONENTS

## SPECIAL SEISMIC CERTIFICATION

**TABLE 1 (continued)**

DOCUMENT NO.: 17101CR1.0

MANUFACTURER: LS ELECTRIC CO., LTD.						
PRODUCT FAMILY: H100 VFD & SP100 VFD BYPASS						
MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>H100 VFD (continued)</b>						
LSLV0550H100-4CEFD+DI	11.2	12.1	35.9	95.0	55kW, 400Vac, Type 1 Disconnect	INTERP
LSLV0550H100-4CEND+DI	11.2	12.1	35.9	95.0	55kW, 400Vac, Type 1 Disconnect	INTERP
LSLV0750H100-4CEND	12.8	12.1	27.0	104.0	75kW, 400Vac, Type 1 Conduit	INTERP
LSLV0900H100-4CEND	12.8	12.1	27.0	104.0	90kW, 400Vac, Type 1 Conduit	<b>UUT 10</b>
LSLV0750H100-4CEND+DI	12.2	12.1	38.6	120.0	75kW, 400Vac, Type 1 Disconnect	INTERP
LSLV0900H100-4CEND+DI	12.2	12.1	38.6	121.0	90kW, 400Vac, Type 1 Disconnect	<b>UUT 11</b>
<b>SP100 VFD Bypass</b>						
LSLV0075SP100-2CEND3	7.1	6.2	29.5	34.0	7.5kW, 200Vac	<b>UUT 1</b>
LSLV0055SP100-2CEND3	7.1	6.2	29.5	38.0	5.5kW, 200Vac	INTERP
LSLV0055SP100-4CEFD3	7.1	6.2	29.5	38.0	5.5kW, 400Vac	INTERP
LSLV0075SP100-4CEFD3	7.1	6.2	29.5	38.0	7.5kW, 400Vac	INTERP
LSLV0110SP100-4CEFD3	7.1	6.2	29.5	38.0	11kW, 400Vac	INTERP
LSLV0110SP100-2CEND3	8.9	7.8	39.3	78.0	11kW, 200Vac	INTERP
LSLV0150SP100-2CEND3	8.9	7.8	39.3	78.0	15kW, 200Vac	INTERP
LSLV0150SP100-4CEFD3	8.9	7.8	39.3	78.0	15kW, 400Vac	INTERP
LSLV0185SP100-4CEFD3	8.9	7.8	39.3	78.0	18.5kWp, 400Vac	INTERP
LSLV0185SP100-2CEND3	10.0	9.4	44.6	93.0	18.5kWp, 200Vac	INTERP
LSLV0220SP100-4CEFD3	10.0	9.4	44.6	93.0	22kW, 400Vac	INTERP
LSLV0300SP100-4CEFD3	10.0	9.4	44.6	107.0	30kW, 400Vac	<b>UUT 4</b>
LSLV0370SP100-4CEND3	12.0	12.9	57.5	159.0	37kW, 400Vac	INTERP
LSLV0450SP100-4CEND3	12.0	12.9	57.5	182.0	45kW, 400Vac	INTERP
LSLV0550SP100-4CEND3	12.0	12.9	57.5	182.0	55kW, 400Vac	<b>UUT 8</b>
<b>MOUNTING:</b> Rigid mounted to rigid or vibration isolation mounted wall.				<b>SEISMIC LEVELS:</b>	$S_{DS} = 2.0g$ for $z/h = 1$ $S_{DS} = 2.5g$ for $z/h = 0$	
<b>NOTES:</b>						
<b>Product Construction:</b> IP20/UL Open or UL Type 1 enclosure (Type 1 is achieved with conduit, disconnect, or bypass).						
<b>Options/Subcomponents:</b> Voltage: 208/230V (nominal 200V) or 460V (nominal 400V). Available subcomponents are listed in Table 2.						
<b>Nomenclature:</b> See Attachment 3 for nomenclature description.						

## ATTACHMENT 1: CERTIFIED SUBCOMPONENTS

## SPECIAL SEISMIC CERTIFICATION

### TABLE 2 - SUBCOMPONENTS

DOCUMENT NO.: 17101CR1.0

MANUFACTURER: LS ELECTRIC CO., LTD.						
PRODUCT FAMILY: H100 VFD & SP100 VFD BYPASS						
MANUFACTURER AND MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>LS Electric - Disconnect Modules</b>						
64160028	6.2	9.8	9.7	7.3	0.75kW-2, HFR1-H100	EXTRAP
64160029	6.2	9.8	9.7	7.3	1.5kW-2, HFR2-H100	EXTRAP
64160030	6.2	9.8	9.7	7.3	2.2kW-2, HFR3-H100	EXTRAP
64160031	6.2	9.8	9.7	7.3	3.7kW-2, HFR4-H100	EXTRAP
64160032	6.2	9.8	9.7	7.3	5.5kW-2, HFR5-H100	EXTRAP
64160033	6.2	9.8	9.7	7.3	7.5kW-2, HFR6-H100	EXTRAP
64160034	6.2	9.8	9.7	8.8	11kW-2, HFR7-H100	EXTRAP
64160037	6.2	11.4	13.2	12.4	0.75kW-4, HFRA-H100	EXTRAP
64160038	6.2	11.4	13.2	12.4	1.5kW-4, HFRB-H100	EXTRAP
64160039	6.2	11.4	13.2	12.4	2.2kW-4, HFRC-H100	EXTRAP
64160040	6.2	11.4	13.2	12.4	3.7kW-4, HFRD-H100	EXTRAP
64160041	6.2	11.4	13.2	12.4	5.5kW-4, HFRE-H100	EXTRAP
64160042	6.2	11.4	13.2	12.4	7.5kW-4, HFRF-H100	EXTRAP
64160043	6.2	11.4	13.2	12.4	11kW-4, HFRG-H100	EXTRAP
64160044	6.2	11.4	13.2	13.0	15kW-4, HFRH-H100	UUT 2
64160045	6.2	11.4	13.2	13.0	18.5kW-4, HFRI-H100	INTERP
64160035	7.0	9.8	11.6	13.5	15kW-2, HFR8-H100	INTERP
64160036	8.5	10.9	12.3	15.0	18.5kW-2, HFR9-H100	UUT 3
64160046	8.5	11.4	14.5	15.0	22kW-4, HFRJ-H100	INTERP
64160047	8.5	11.4	14.5	15.0	30kW-4, HFRK-H100	INTERP
64160048	10.7	13.4	15.0	20.9	37kW-4, HFRL-H100	INTERP
64160049	12.6	13.4	15.8	23.6	45kW-4, HFRM-H100	INTERP
64160050	12.6	13.4	15.8	23.6	55kW-4, HFRN-H100	INTERP
64160051	12.6	14.4	16.9	26.9	75kW-4, HFRO-H100	INTERP
64160052	12.6	14.4	16.9	26.9	90kW-4, HFRP-H100	UUT 11
<b>LS Electric - Capacitor PCB</b>						
10120003822	3.5	5.8		<1	LSLV-S100,055-4	EXTRAP
10120003824	3.5	5.8		<1	LSLV-S100,075-4	EXTRAP
10120003821	3.5	5.8		1.1	LSLV-S100,055-2	UUT 1
10120003823	3.5	5.8		1.1	LSLV-S100,075-2	INTERP
10120003825	3.5	5.8		1.1	LSLV-S100,110-2	INTERP
10120003826	3.5	5.8		1.5	LSLV-S100,110-4	UUT 2
10120003827	3.9	6.6		1.8	LSLV-S100,150-2	UUT 3
10120003828	3.9	6.6		2.1	LSLV-S100,150-4	INTERP
10120003830	3.9	6.6		2.1	LSLV-S100,185-4	INTERP
10120003831	4.7	7.9		3.0	LSLV-S100,220-4	UUT 4,5
<b>Metasol - Contactor</b>						
13370032	3.5	2.7	3.3	1.2	MC-40a AC24V 60Hz SCREW	UUT 1
13390032	4.7	3.1	4.2	2.3	MC-65a AC24V 60Hz SCREW	INTERP
13620002	5.1	4.7	6.2	5.3	MC-130a AC24V 50/60Hz SCREW	UUT 4
13640002	5.1	4.7	6.2	5.3	MC-150a AC24V 50/60Hz SCREW	UUT 8
<b>NOTES:</b> Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.						

## ATTACHMENT 1: CERTIFIED SUBCOMPONENTS

## SPECIAL SEISMIC CERTIFICATION

### TABLE 2 - SUBCOMPONENTS (continued)

DOCUMENT NO.: 17101CR1.0

MANUFACTURER: LS ELECTRIC CO., LTD.						
PRODUCT FAMILY: H100 VFD & SP100 VFD BYPASS						
MANUFACTURER AND MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>Kosed - DC Reactors</b>						
22910000872	2.8	2.6	2.3	2.5	26.3A, 0.81mH, 055SP100-2	EXTRAP
22910000873	2.8	2.6	2.3	2.5	13.2A, 3.7mH, 055SP100-4	EXTRAP
22910000875	3.1	3.0	2.6	3.6	16.9A, 3.2mH, 075SP100-4	EXTRAP
22910000876	3.1	3.0	2.6	3.6	52A, 0.6mH, 110SP100-2	EXTRAP
22910000874	3.1	3.0	2.6	3.9	34.9A, 0.79mH, 075SP100-2	UUT 1
22910000877	3.1	3.0	2.6	4.1	27.6A, 2.4mH, 110SP100-4	INTERP
22910000882	3.0	5.3	2.6	5.6	32A, 1.4mH, 150SP100-4	INTERP
22910000881	3.0	5.3	2.6	6.1	64A, 0.44mH, 150SP100-2	INTERP
22910000883	3.0	5.3	2.6	6.2	40.7A, 1.15mH, 185SP100-4	INTERP
22910000888	3.0	5.3	2.6	6.3	49A, 1mH, 220SP100-4	INTERP
22910000887	3.0	5.3	2.6	6.7	83.8A, 0.35mH, 185SP100-2	INTERP
22910000889	3.0	6.7	2.6	9.2	62.2A, 0.6mH, 300SP100-4	UUT 4
22910000751	3.8	5.1	3.3	9.6	LSLV0300S100-4,92A,0.51mH	UUT 6
22910000752	3.8	6.3	3.3	16.0	LSLV0370S100-4,115A,0.42mH	UUT 7
22910000753	3.8	6.3	3.3	16.0	LSLV0450S100-4,135A,0.35mH	UUT 8
22910000754	3.8	6.3	3.7	18.0	LSLV0550S100-4,185A,0.26mH	UUT 9
22910000755	3.8	7.5	3.7	23.0	LSLV0750S100-4,218A,0.22mH	UUT 10,11
<b>Huawei - Main Capacitor</b>						
08810002699	5.1	3.0	3.1	4.1	400V,6800UF	UUT 7
08810002700	5.1	3.0	3.1	4.1	400V,5600UF	UUT 6
08810002701	5.1	3.0	3.1	4.1	400V,8200UF	UUT 8
08810002699	5.1	3.0	3.1	8.3	400V,6800UF	UUT 10,11
08810002700	5.1	3.0	3.1	8.3	400V,5600UF	UUT 9
<b>LS Electric - Manual Motor Starter</b>						
7051044	3.9	1.8	3.9	<1	MMS-32H 8A	EXTRAP
7051046	3.9	1.8	3.9	<1	MMS-32H 13A	EXTRAP
7051047	3.9	1.8	3.9	<1	MMS-32H 17A	EXTRAP
7051048	3.9	1.8	3.9	<1	MMS-32H 22A	EXTRAP
7051050	3.9	1.8	3.9	<1	MMS-32H 32A	EXTRAP
7051051	3.9	1.8	3.9	<1	MMS-32H 40A	UUT 1
7061018	5.5	2.2	5.7	2.2	MMS-63H 50A	INTERP
7071018	6.5	2.8	6.7	4.9	MMS-32H 75A	INTERP
7070019	6.5	2.8	6.7	4.9	MMS-100H 90A	UUT 3
<b>LS Electric - Circuit Breakers</b>						
02070354UL	6.5	4.1	4.4	3.7	UTS150L MCP 40A 3P UL	UUT 2
02070355UL	6.5	4.1	4.4	3.7	UTS150L MCP 50A 3P UL	INTERP
02070356UL	6.5	4.1	4.4	3.7	UTS150L MCP 60A 3P UL	INTERP
02070358UL	6.5	4.1	4.4	3.7	UTS150L MCP 80A 3P UL	INTERP
02070368UL	6.5	4.1	4.4	3.7	UTS150L MCP 100A 3P UL	UUT 4
02070369UL	6.5	4.1	4.4	3.7	UTS150L MCP 150A 3P UL	UUT 8
02070459UL	6.5	4.1	4.4	3.7	UTS150L MCP 125A 3P UL	INTERP
02090226UL	6.5	4.1	4.4	3.7	UTS150L MCP 175A 3P UL	INTERP
<b>NOTES:</b> Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.						

**ATTACHMENT 1: CERTIFIED SUBCOMPONENTS**
**SPECIAL SEISMIC CERTIFICATION**
**TABLE 2 - SUBCOMPONENTS (continued)**
**DOCUMENT NO.: 17101CR1.0**

MANUFACTURER: LS ELECTRIC CO., LTD.						
PRODUCT FAMILY: H100 VFD & SP100 VFD BYPASS						
MANUFACTURER AND MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>LS Electric - Circuit Breakers (continued)</b>						
02090228UL	6.5	4.1	4.4	3.7	UTS150L MCP 225A 3P UL	UUT 11
<b>Wabash - Transformers</b>						
73016296006	3.1	3.8	2.2	4.2	Power trans, CL100K05-000-VXC	UUT 1,4,8
<b>LS Electric - EMC Filter</b>						
9710000540	3.7	8.2		1.6	LSLV0300S100-4,42UH	UUT 6
9710000541	3.9	8.4		2.2	LSLV0370/0450S100-4,34UH	UUT 7
<b>LS Electric - Power PCB</b>						
10120004346	5.9	4.9		<1	LSLV-S100,0300-4	UUT 6
10120004553	8.3	6.1		1.7	LSLV-H100,0055-2	INTERP
10120004554	8.3	6.1		1.7	LSLV-H100,0075-2	UUT 1
10120004555	8.3	6.1		1.7	LSLV-H100,0110-2	INTERP
10120004556	10.6	6.9		1.7	LSLV-H100,0150-2	INTERP
10120004558	8.3	6.1		1.7	LSLV-H100,0055-4	INTERP
10120004559	8.3	6.1		1.7	LSLV-H100,0075-4	INTERP
10120004560	8.3	6.1		1.7	LSLV-H100,0110-4	INTERP
10120004561	10.6	6.9		2.1	LSLV-H100,0150-4	UUT 2
10120004562	10.6	6.9		2.1	LSLV-H100,0185-4	INTERP
10120004557	12.7	8.4		2.4	LSLV-H100,0185-2	UUT 3
10120004563	12.7	8.4		2.5	LSLV-H100,0220-4	INTERP
10120004564	12.7	8.4		2.5	LSLV-H100,0300-4	UUT 4,5
<b>LS Electric - OL Detectors</b>						
38060132	2.6	2.8	3.0	<1	GMP60-T 6A 220V 1c[N]	UUT 4,8
38060133	2.6	2.8	3.0	<1	GMP60-T 30A 220V 1c[N]	INTERP
38060134	2.6	2.8	3.0	<1	GMP60-T 60A 220V 1c[N]	UUT 1
<b>Honeywell - Thermal Overload Devices</b>						
6110000126	2.9	1.4	2.6	<1	GCB PART,GCP-32ANM5A	UUT 1,4,8
<b>Osada - Terminal Blocks</b>						
10060001237	2.0	4.9	1.4	<1	OK-060-6P,6P	UUT 1,4
10060002056	2.4	7.4	1.6	<1	OK-0100S-6P,6P	UUT 8
<b>LS Electric - Auxiliary Contact</b>						
83361634001	0.5	2.8	2.7	<1	UA-1,1A1B	UUT 1,4,8
<b>LS Electric - Interlock Unit</b>						
83411634001	0.5	3.3	3.2	<1	UR-02,MC-6aR~150aR	UUT 1,4,8
<b>Infineon - PIM/IGBT</b>						
08910000855	1.8	4.2	0.8	<1	PIM,FP35R12KT4,1200V,35A,B	EXTRAP
08910000856	1.8	4.2	0.8	<1	PIM,FP50R12KT4,1200V,50A,B	UUT 2
08910000858	2.4	4.8	0.8	<1	PIM,FP100R12KT4,1200V,100A,B	UUT 4,5
<b>Fuji - PIM/IGBT</b>						
8910000851	1.8	4.2	0.8	<1	PIM,7MBR75VP060-50,600V	UUT 1
8910000852	1.8	4.2	0.8	<1	PIM,7MBR100VP060-50,600V	INTERP
8910000853	2.4	4.8	0.8	<1	PIM,7MBR150VR060-50,600V	UUT 3
8910001102	2.4	4.8	0.7	<1	IGBT,6MBI150VB-120-50-M,1200V	UUT 6

**NOTES:** Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.

## ATTACHMENT 1: CERTIFIED SUBCOMPONENTS

## SPECIAL SEISMIC CERTIFICATION

### TABLE 2 - SUBCOMPONENTS (continued)

DOCUMENT NO.: 17101CR1.0

MANUFACTURER: LS ELECTRIC CO., LTD.						
PRODUCT FAMILY: H100 VFD & SP100 VFD BYPASS						
MANUFACTURER AND MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>Fuji - PIM/IGBT (continued)</b>						
8910001101	2.4	5.9	0.7	<1	IGBT,2MBI225VN-120-50-M,1200V	UUT 8,9
8910001100	2.4	5.9	0.7	<1	IGBT,2MBI300VN-120-50-M,1200V	UUT 10,11
<b>LS Electric - Main Power Assembly</b>						
10120004553	8.3	6.1		<1	LSLV0008~0055H100-2	EXTRAP
10120004554	8.3	6.1		<1	LSLV0075H100-2	UUT 1
10120004555	8.3	6.1		<1	LSLV0110H100-2	INTERP
10120004556	10.6	6.9		<1	LSLV0150H100-2	INTERP
10120004557	12.7	8.4		<1	LSLV0185H100-2	UUT 3
10120004558	8.3	6.1		<1	LSLV0008~0055H100-4	INTERP
10120004559	8.3	6.1		<1	LSLV0075H100-4	INTERP
10120004560	8.3	6.1		<1	LSLV0110H100-4	INTERP
10120004561	10.6	6.9		<1	LSLV0150H100-4	UUT 2
10120004562	10.6	6.9		<1	LSLV0185H100-4	INTERP
10120004563	12.7	8.4		<1	LSLV0220H100-4	INTERP
10120004564	12.7	8.4		<1	LSLV0300H100-4	UUT 4,5
<b>LS Electric - Control PCB</b>						
10120004581	3.1	2.3		<1	LSLV-H100,0370~0900-4	UUT 6-11
<b>LS Electric - Main PCB</b>						
10120004566	7.5	5.4		<1	LSLV-H100,0370-4	UUT 6
10120004567	5.8	5.4		<1	LSLV-H100,0450-4	UUT 7
10120004568	5.8	5.4		<1	LSLV-H100,0550-4	UUT 8
10120004569	6.1	5.8		<1	LSLV-H100,0750-4	UUT 9
10120004580	6.1	5.8		<1	LSLV-H100,0900-4	UUT 10,11
<b>LS Electric - Gate Drive</b>						
10120006332	2.4	3.9		<1	LSLV-H100,0450~0750-4	UUT 7-9
10120006333	2.4	3.9		<1	LSLV-H100,0900-4	UUT 10,11
<b>LS Electric - Input PCB</b>						
10120003803	1.9	6.0		<1	LSLV-S100,055/075-2	UUT 1
10120003804	2.0	6.8		<1	LSLV-S100,110-2	INTERP
10120003805	3.0	8.2		<1	LSLV-S100,150-2	UUT 3
10120003806	3.3	4.5		<1	LSLV-S100,055/075-4	INTERP
10120003807	3.9	5.6		<1	LSLV-S100,110/150-4	UUT 2
10120003808	4.1	6.2		<1	LSLV-S100,185/220-4	UUT 4,5
<b>LS Electric - CT PCB</b>						
10120004349	1.9	5.4	1.1	<1	LSLV-S100,0370-4	UUT 7
10120004361	1.9	5.4	1.1	<1	LSLV-S100,0450-4	UUT 8
<b>LS Electric - Snubber PCB</b>						
10120004347	1.7	2.1	1.2	<1	LSLV-S100,0300~0450-4	UUT 6-8
10120004353	1.3	4.2	1.2	<1	LSLV-S100,0550/0750-4	UUT 9-11
<b>LS Electric - Fan SMPS</b>						
10120004352	2.4	6.3		<1	-S100,0550/0750-4	UUT 9-11

**NOTES:** Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.

**ATTACHMENT 1: CERTIFIED SUBCOMPONENTS**
**SPECIAL SEISMIC CERTIFICATION**
**TABLE 2 - SUBCOMPONENTS (continued)**
**DOCUMENT NO.: 17101CR1.0**

MANUFACTURER: LS ELECTRIC CO., LTD.						
PRODUCT FAMILY: H100 VFD & SP100 VFD BYPASS						
MANUFACTURER AND MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>Sanrex - Diode Module</b>						
08960001321	1.0	3.7	1.2	<1	DD100KB160,1600V,100A,B	UUT 9-11
08960001322	2.0	4.3	0.7	<1	DF150AC160,1600V,150A,B	UUT 6,7
08960001323	2.0	4.3	0.7	<1	DF200AC160,1600V,200A,B	UUT 8
<b>LS Electric - I/O CPU</b>						
10120004549	4.0	4.5		<1	SV-H100,5.5~30kW	UUT 1-5
10120004550	4.7	5.1		<1	SV-H100,37~90kW	UUT 6-11
<b>LS Electric - I/O TB</b>						
10120004551	1.9	3.9		<1	SV-H100,5.5~90kW	UUT 1-11
<b>LS Electric - Cover Power</b>						
64626294114	3.5	6.3	2.0	<1	055/075/110H100-2/4	UUT 1
64626294117	5.3	7.0	2.0	<1	150H100-2/4, 185H100-4	UUT 2
64626294120	7.3	8.6	2.0	<1	185H100-2, 220/300H100-4	UUT 3-5
64626294123	7.6	10.7	1.5	<1	370H100-4,VF7929012	UUT 6
64626294126	9.4	12.7	1.5	<1	450/550H100-4,VF7929015	UUT 7,8
64626294129	10.8	12.8	1.5	<1	750/900H100-4,VF7929018	UUT 9-11
<b>LS Electric - Terminal Block</b>						
62776224001	1.6	10.6	2.4	1.7	LSLV0300S100-4	UUT 6
62776224002	2.2	12.4	1.6	2.1	LSLV0370/0450S100-4	UUT 8
62776224004	2.2	12.4	1.6	2.1	LSLV0370/0450S100-4	UUT 7
62776224003	3.1	12.4	1.7	2.5	LSLV0550S100-4	UUT 9
62776224005	3.1	12.4	1.7	2.5	LSLV0750S100-4	UUT 10,11
<b>DCC - Fan</b>						
7760000244	2.4	2.4	1.0	<1	F6025X24B0-AH-PC,DC24V	UUT 1
<b>Nidec - Fans</b>						
7760000172	3.6	3.6	1.5	<1	V35131-51LS,DC24V,92SQ*38MM	UUT 3-8
7760000299	2.8	2.8	1.0	<1	D08A-24TS2 15(K),DC24V	UUT 2
<b>NMB - Fan</b>						
7760000272	4.7	4.7	1.5	<1	12038VA-24P-EL-01,DC24V	UUT 9-11
<b>Shizuki - Snubber Capacitor</b>						
8810002338	1.8	1.9	1.5	<1	UB12X185JM5XSA,DC1200V	UUT 6-11
<b>LS Electric - Capacitor Bank</b>						
50826224001	6.1	8.9	5.1	6.2	LSLV0300S100-4,VF8073049	UUT 6
50826224002	6.1	10.9	5.2	6.3	LSLV0370S100-4,VF8073050	UUT 7
50826224004	6.1	10.9	5.2	6.4	LSLV0450S100-4,VF8073087	UUT 8
50826224003	6.1	10.9	7.8	11.4	LSLV0550S100-4,VF8073051	UUT 9
50826224005	6.1	10.9	7.8	12.2	LSLV0750S100-4,VF8073088	UUT 10,11
<b>LS Electric - Busbar</b>						
70226225012	3.3	4.6	3.3	<1	IGBT,LSLV0300S100-4	UUT 6
70226224037	1.5	12.1	2.9	<1	P1P2,LSLV0300S100-4,	UUT 6
70226224038	2.7	11.0	8.8	<1	LSLV0370/0450S100-4	UUT 7,8
70226224039	1.6	13.6	4.1	<1	P1P2,LSLV0370/0450S100-4	UUT 7,8
70226224036	3.5	9.3	3.4	<1	RST,LSLV0300S100-4	INTERP

**NOTES:** Table continues on the next page. Additional notes, information, and seismic parameters are shown at the end of the table.

**ATTACHMENT 1: CERTIFIED SUBCOMPONENTS**

**SPECIAL SEISMIC CERTIFICATION**

**TABLE 2 - SUBCOMPONENTS (continued)**

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER: LS ELECTRIC CO., LTD.</b>						
<b>PRODUCT FAMILY: H100 VFD &amp; SP100 VFD BYPASS</b>						
MANUFACTURER AND MODEL NUMBER	DIMENSIONS (in)			MAX. WT. (lb)	DESCRIPTION / NOTES	BASIS
	DEPTH	WIDTH	HEIGHT			
<b>LS Electric - Busbar (continued)</b>						
70226224035	2.3	5.4	7.9	1.0	LSLV0300S100-4	UUT 6
70226224040	3.9	11.8	15.3	2.0	LSLV0550/0750S100-4	UUT 9-11
<b>LS Electric - Busbar Diode</b>						
70216225048	1.4	0.5	2.3	<1	LSLV0300~0450S100-4	UUT 6,7
<b>LS Electric - LED Bar</b>						
63466295001	0.9	0.5	0.2	<1	055~900H100,VF7925601	UUT 1-11
<b>LS Electric - Noise Filter Circuit Assembly</b>						
77026236100	23.0	12.0	6.0	<1	Z-TRAP/N-FILTER 400V	UUT 6-11
<b>LS Electric - LCD Keypad</b>						
11040002604	2.6	4.1		<1		UUT 1-11
<b>MOUNTING:</b> Mounted within unit.				<b>SEISMIC LEVELS:</b>	$S_{DS} = 2.0g$ for $z/h = 1$ $S_{DS} = 2.5g$ for $z/h = 0$	$I_p = 1.5$
<b>NOTES: Construction/Options:</b> Model number uniquely identifies manufacturer, materials, and configuration of subcomponents.						

## ATTACHMENT 2: TESTING SUMMARY

## SPECIAL SEISMIC CERTIFICATION

### TEST UNITS

DOCUMENT NO.: 17101CR1.0

UUT	MODEL NUMBER	DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)			TEST RUNS
		DEPTH	WIDTH	HEIGHT		F-B	S-S	V	
UUT 1	LSLV0075SP100-2CEND3	7.1	6.2	29.5	34	N/A	N/A	N/A	1 & 2
UUT 2	LSLV0150H100-4CEFN+DI	9.2	7.1	24.6	24	N/A	N/A	N/A	1 & 2
UUT 3	LSLV0185H100-2CENN+DI	9.2	8.7	23.0	30	N/A	N/A	N/A	1 & 2
UUT 4	LSLV0300SP100-4CEFD3	10.0	9.4	44.6	107	N/A	N/A	N/A	1 & 2
UUT 5	LSLV0300H100-4CEFN+FL	8.8	8.7	15.1	21	N/A	N/A	N/A	1 & 2
UUT 6	LSLV0370H100-4CEFD	11.2	10.8	20.5	60	N/A	N/A	N/A	1 & 2
UUT 7	LSLV0450H100-4COFD	11.2	12.1	20.1	75	N/A	N/A	N/A	1 & 2
UUT 8	LSLV0550SP100-4CEND3	12.0	12.9	57.5	182	N/A	N/A	N/A	1 & 2
UUT 9	LSLV0750H100-4COND+FL	12.8	12.1	21.7	92	N/A	N/A	N/A	1 & 2
UUT 10	LSLV0900H100-4CEND	12.8	12.1	27.0	104	N/A	N/A	N/A	1 & 2
UUT 11	LSLV0900H100-4CEND+DI	12.2	12.1	38.6	121	N/A	N/A	N/A	1 & 2

### TEST RUNS

<b>RUN DESCRIPTION:</b>	RUN 1 - RIGID
<b>TESTED UNITS:</b>	UUT 1 - UUT 11 (listed with 'a' in summaries)
<b>CODE &amp; CRITERIA:</b>	2022 CBC, ICC-ES AC156
<b>TEST LABORATORY:</b>	ENVIRONMENTAL TESTING LABORATORY
<b>REPORT:</b>	17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019

S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
2.0	1	3.20	2.40	1.68	0.68
2.5	0				

**MOUNTING & NOTES:**  
Test fixture was rigid mounted to the table. All UUTs were rigid wall mounted to the fixture (see individual UUT Summaries for details).



<b>RUN DESCRIPTION:</b>	RUN 2 - ISOLATED
<b>TESTED UNITS:</b>	UUT 1 - UUT 11 (listed with 'b' in summaries)
<b>CODE &amp; CRITERIA:</b>	2022 CBC, ICC-ES AC156
<b>TEST LABORATORY:</b>	ENVIRONMENTAL TESTING LABORATORY
<b>REPORT:</b>	17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019

S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
2.0	1	3.20	2.40	1.68	0.68
2.5	0				

**MOUNTING & NOTES:**  
Test fixture was mounted to table using (4) Mason SSLFHC spring isolators. All UUTs were rigid wall mounted to the fixture (see individual UUT Summaries for details).



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 1a - RIGID

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0075SP100-2CEND3				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
7.1	6.2	29.5	34	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) #10 wood screws. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		LS Electric - H100 Open VFD (LSLV0075H100-2CONN), LS Electric - capacitor PCB (10120003821), Metasol - contactor (13370032), Kosed - DC reactors (22910000874), LS Electric - manual motor starter (7051051), Wabash - transformer (73016296006), LS Electric - power PCB (10120004554), LS Electric - OL detector (38060134), Honeywell - thermal overload device (6110000126), Osada - terminal block (10060001237), LS Electric - auxiliary contact (83361634001), LS Electric - interlock unit (83411634001), Fuji - PIM/IGBT (8910000851), LS Electric - main power assembly (10120004554), LS Electric - input PCB (10120003803), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294114), DCC - fan (7760000244), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 1b - ISOLATED

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0075SP100-2CEND3				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
7.1	6.2	29.5	34	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) #10 wood screws. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 1a. Only fixture mounting varies.				



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 2a - RIGID

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0150H100-4CEFN+DI				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
9.2	7.1	24.6	24	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (6) #10 wood screws. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		LS Electric - disconnect modules (64160044), LS Electric - capacitor PCB (10120003826), LS Electric - circuit breaker (02070354UL), LS Electric - power PCB (10120004561), Infineon - PIM/IGBT (08910000856), LS Electric - main power assembly (10120004561), LS Electric - input PCB (10120003807), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294117), Nidec - fan (7760000299), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 2b - ISOLATED

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0150H100-4CEFN+DI				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
9.2	7.1	24.6	24	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (6) #10 wood screws. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 2a. Only fixture mounting varies.				



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 3a - RIGID


DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0185H100-2CENN+DI				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
<b>DIMENSIONS (in)</b>			<b>WEIGHT (lb)</b>	<b>RES. FREQ. (Hz)</b>		
<b>DEPTH</b>	<b>WIDTH</b>	<b>HEIGHT</b>		<b>F-B</b>	<b>S-S</b>	<b>V</b>
9.2	8.7	23.0	30	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
<b>S<sub>DS</sub> (g)</b>	<b>z/h</b>	<b>A<sub>FLX-H</sub> (g)</b>	<b>A<sub>RIG-H</sub> (g)</b>	<b>A<sub>FLX-V</sub> (g)</b>	<b>A<sub>RIG-V</sub> (g)</b>	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (6) #10 wood screws. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		LS Electric - disconnect modules (64160036), LS Electric - capacitor PCB (10120003827), LS Electric - manual motor starter (7070019), LS Electric - power PCB (10120004557), Fuji - PIM/IGBT (8910000853), LS Electric - main power assembly (10120004557), LS Electric - input PCB (10120003805), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294120), Nidec - fan (7760000172), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 3b - ISOLATED

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0185H100-2CENN+DI				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
<b>DIMENSIONS (in)</b>			<b>WEIGHT (lb)</b>	<b>RES. FREQ. (Hz)</b>		
<b>DEPTH</b>	<b>WIDTH</b>	<b>HEIGHT</b>		<b>F-B</b>	<b>S-S</b>	<b>V</b>
9.2	8.7	23.0	30	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
<b>S<sub>DS</sub> (g)</b>	<b>z/h</b>	<b>A<sub>FLX-H</sub> (g)</b>	<b>A<sub>RIG-H</sub> (g)</b>	<b>A<sub>FLX-V</sub> (g)</b>	<b>A<sub>RIG-V</sub> (g)</b>	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (6) #10 wood screws. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 3a. Only fixture mounting varies.				



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 4a - RIGID

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0300SP100-4CEFD3				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
10.0	9.4	44.6	107	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) #10 wood screws. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		LS Electric - H100 Open VFD (LSLV0300H100-4COFN), LS Electric - capacitor PCB (10120003831), Metasol - contactor (13620002), Kosed - DC reactors (22910000889), LS Electric - circuit breaker (02070368UL), Wabash - transformer (73016296006), LS Electric - power PCB (10120004564), LS Electric - OL detector (38060132), Honeywell - thermal overload device (6110000126), Osada - terminal block (10060001237), LS Electric - auxiliary contact (83361634001), LS Electric - interlock unit (83411634001), Infineon - PIM/IGBT (08910000858), LS Electric - main power assembly (10120004564), LS Electric - input PCB (10120003808), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294120), Nidec - fan (7760000172), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 4b - ISOLATED

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0300SP100-4CEFD3				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
10.0	9.4	44.6	107	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) #10 wood screws. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 4a. Only fixture mounting varies.				




## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 5a - RIGID

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0300H100-4CEFN+FL				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
8.8	8.7	15.1	21	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) #10 wood screws. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		LS Electric - capacitor PCB (10120003831), LS Electric - power PCB (10120004564), Infineon - PIM/IGBT (08910000858), LS Electric - main power assembly (11040002616), LS Electric - input PCB (10120003808), LS Electric - I/O CPU (10120004549), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294120), Nidec - fan (7760000172), LS Electric - LED bar (63466295001), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 5b - ISOLATED

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0300H100-4CEFN+FL				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
8.8	8.7	15.1	21	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) #10 wood screws. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 5a. Only fixture mounting varies.				



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 6a - RIGID

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0370H100-4CEFD				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
11.2	10.8	20.5	60	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) 1/4-in lag bolts. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		Kosed - DC reactors (22910000751), Huawei - main capacitor (08810002700), LS Electric - EMC filter (9710000540), LS Electric - power PCB (10120004346), Fuji - PIM/IGBT (8910001102), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004566), LS Electric - snubber PCB (10120004347), Sanrex - diode module (08960001322), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294123), LS Electric - terminal block (62776224001), Nidec - fan (7760000172), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224001), LS Electric - busbar (70226224035, 70226224037, 70226225012), LS Electric - busbar diode (70216225048), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 6b - ISOLATED

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0370H100-4CEFD				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
11.2	10.8	20.5	60	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) 1/4-in lag bolts. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 6a. Only fixture mounting varies.				




## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 7a - RIGID

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0450H100-4COFD				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
11.2	12.1	20.1	75	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) 1/4-in lag bolts. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		Kosed - DC reactors (22910000752), Huawei - main capacitor (08810002699), LS Electric - EMC filter (9710000541), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004567), LS Electric - gate drive (10120006332), LS Electric - CT PCB (10120004349), LS Electric - snubber PCB (10120004347), Sanrex - diode module (08960001322), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294126), LS Electric - terminal block (62776224004), Nidec - fan (7760000172), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224002), LS Electric - busbar (70226224038, 70226224039), LS Electric - busbar diode (70216225048), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 7b - ISOLATED

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0450H100-4COFD				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
11.2	12.1	20.1	75	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) 1/4-in lag bolts. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 7a. Only fixture mounting varies.				



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 8a - RIGID

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>	LS ELECTRIC CO., LTD.
<b>MODEL NUMBER:</b>	LSLV0550SP100-4CEND3
<b>UNIT FUNCTION:</b>	VARIABLE FREQUENCY DRIVE
<b>SERIAL NUMBER:</b>	N/A

DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
12.0	12.9	57.5	182	N/A	N/A	N/A

**CODE & CRITERIA:** 2022 CBC, ICC-ES AC156

**TEST LABORATORY:** ENVIRONMENTAL TESTING LABORATORY

**REPORT:** 17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019

S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
2.0	1	3.20	2.40	1.68	0.68
2.5	0				

**IMPORTANCE FACTOR, I<sub>p</sub> = 1.5**

Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.



**MOUNTING:** Wall mounted using (4) 5/16-in lag bolts. Test fixture was rigid mounted to the table.

**CONSTRUCTION:** Carbon steel and plastic construction.

**SUBCOMPONENTS:** LS Electric - H100 Open VFD (LSLV0550H100-4COND), Metasol - contactor (13640002), Kosed - DC reactors (22910000753), Huawei - main capacitor (08810002701), LS Electric - circuit breaker (02070369UL), Wabash - transformer (73016296006), LS Electric - OL detector (38060132), Honeywell - thermal overload device (6110000126), Osada - terminal block (10060002056), LS Electric - auxiliary contact (83361634001), LS Electric - interlock unit (83411634001), Fuji - PIM/IGBT (8910001101), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004568), LS Electric - gate drive (10120006332), LS Electric - CT PCB (10120004361), LS Electric - snubber PCB (10120004347), Sanrex - diode module (08960001323), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294126), LS Electric - terminal block (62776224002), Nidec - fan (7760000172), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224004), LS Electric - busbar (70226224038, 70226224039), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)

**TESTING NOTES:** N/A

## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 8b - ISOLATED

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>	LS ELECTRIC CO., LTD.
<b>MODEL NUMBER:</b>	LSLV0550SP100-4CEND3
<b>UNIT FUNCTION:</b>	VARIABLE FREQUENCY DRIVE
<b>SERIAL NUMBER:</b>	N/A

DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
12.0	12.9	57.5	182	N/A	N/A	N/A

**CODE & CRITERIA:** 2022 CBC, ICC-ES AC156

**TEST LABORATORY:** ENVIRONMENTAL TESTING LABORATORY

**REPORT:** 17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019

S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)
2.0	1	3.20	2.40	1.68	0.68
2.5	0				

**IMPORTANCE FACTOR, I<sub>p</sub> = 1.5**  
 Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

**MOUNTING:** Wall mounted using (4) 5/16-in lag bolts. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.

**TESTING NOTES:** UUT is the same physical unit as the rigid mounted UUT 8a. Only fixture mounting varies.



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 9a - RIGID

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0750H100-4COND+FL				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
12.8	12.1	21.7	92	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) 5/16-in lag bolts. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		Kosed - DC reactors (22910000754), Huawei - main capacitor (08810002700), Fuji - PIM/IGBT (8910001101), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004569), LS Electric - gate drive (10120006332), LS Electric - snubber PCB (10120004353), LS Electric - fan SMPS (10120004352), Sanrex - diode module (08960001321), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294129), LS Electric - terminal block (62776224003), NMB - fan (7760000272), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224003), LS Electric - busbar (70226224040), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 9b - ISOLATED

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0750H100-4COND+FL				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
12.8	12.1	21.7	92	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) 5/16-in lag bolts. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 9a. Only fixture mounting varies.				




## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 10a - RIGID

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0900H100-4CEND				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
12.8	12.1	27.0	104	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) 5/16-in lag bolts. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		Kosed - DC reactors (22910000755), Huawei - main capacitor (08810002699), Fuji - PIM/IGBT (8910001100), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004580), LS Electric - gate drive (10120006333), LS Electric - snubber PCB (10120004353), LS Electric - fan SMPS (10120004352), Sanrex - diode module (08960001321), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294129), LS Electric - terminal block (62776224005), NMB - fan (7760000272), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224005), LS Electric - busbar (70226224040), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 10b - ISOLATED

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0900H100-4CEND				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
12.8	12.1	27.0	104	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (4) 5/16-in lag bolts. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 10a. Only fixture mounting varies.				



## ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

## SPECIAL SEISMIC CERTIFICATION

### UUT 11a - RIGID

DOCUMENT NO.: 17101CR1.0


<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0900H100-4CEND+DI				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
12.2	12.1	38.6	121	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (6) 5/16-in lag bolts. Test fixture was rigid mounted to the table.				
<b>CONSTRUCTION:</b>		Carbon steel and plastic construction.				
<b>SUBCOMPONENTS:</b>		LS Electric - disconnect modules (64160052), Kosed - DC reactors (22910000755), Huawei - main capacitor (08810002699), LS Electric - circuit breaker (02090228UL), Fuji - PIM/IGBT (8910001100), LS Electric - control PCB (10120004581), LS Electric - main PCB (10120004580), LS Electric - gate drive (10120006333), LS Electric - snubber PCB (10120004353), LS Electric - fan SMPS (10120004352), Sanrex - diode module (08960001321), LS Electric - I/O CPU (10120004550), LS Electric - I/O TB (10120004551), LS Electric - cover power (64626294129), LS Electric - terminal block (62776224005), NMB - fan (7760000272), Shizuki - snubber capacitor (8810002338), LS Electric - capacitor bank (50826224005), LS Electric - busbar (70226224040), LS Electric - LED bar (63466295001), LS Electric - noise filter circuit assembly (77026236100), LS Electric - LCD keypad (11040002604)				
<b>TESTING NOTES:</b>		N/A				



### UUT 11b - ISOLATED

DOCUMENT NO.: 17101CR1.0

<b>MANUFACTURER:</b>		LS ELECTRIC CO., LTD.				
<b>MODEL NUMBER:</b>		LSLV0900H100-4CEND+DI				
<b>UNIT FUNCTION:</b>		VARIABLE FREQUENCY DRIVE				
<b>SERIAL NUMBER:</b>		N/A				
DIMENSIONS (in)			WEIGHT (lb)	RES. FREQ. (Hz)		
DEPTH	WIDTH	HEIGHT		F-B	S-S	V
12.2	12.1	38.6	121	N/A	N/A	N/A
<b>CODE &amp; CRITERIA:</b>		2022 CBC, ICC-ES AC156				
<b>TEST LABORATORY:</b>		ENVIRONMENTAL TESTING LABORATORY				
<b>REPORT:</b>		17101TR1.0, Rev. 0 (dated 06/23/23), tested on 12/11/2019				
S <sub>DS</sub> (g)	z/h	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
2.0	1	3.20	2.40	1.68	0.68	
2.5	0					
<b>IMPORTANCE FACTOR, I<sub>p</sub> = 1.5</b>						
Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.						
<b>MOUNTING:</b>		Wall mounted using (6) 5/16-in lag bolts. Test fixture was mounted to table using (4) Mason SSLFHC spring isolators.				
<b>TESTING NOTES:</b>		UUT is the same physical unit as the rigid mounted UUT 11a. Only fixture mounting varies.				



## ATTACHMENT 3: MODEL NOMENCLATURE

## SPECIAL SEISMIC CERTIFICATION

### H100 VFD

DOCUMENT NO.: 17101CR1.0

DIGIT:	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	-	-	-	-	-	-	-	-
SAMPLE:	L	S	L	V	0	9	0	0	H	1	0	0	-	4	C	E	N	D	+	D	I	-	-	-	-	-	-	-	-
DIGIT	DIGIT DESCRIPTION										CODES		DEFINITIONS																
1-4	Product Type Prefix										LSLV																		
5-8	Power Rating										0008		0.75kW (1hp)																
											0015		1.5kW (2hp)																
											0022		2.2kW (3hp)																
											0037		3.7kW (5hp)																
											0055		5.5kW (7.5hp)																
											0075		7.5kW (10hp)																
											0110		11kW (15hp)																
											0150		15kW (20hp)																
											0185		18.5kW (25hp)																
											0220		22kW (30hp)																
											0300		30kW (40hp)																
											0370		37kW (50hp)																
											0450		45kW (60hp)																
											0550		55kW (75hp)																
0750		75kW (100hp)																											
0900		90kW (125hp)																											
9-13	Series Name										H100-																		
14	Input Voltage										2		200Vac (nominal), 3-Phase, 60Hz																
											4		400Vac (nominal), 3-Phase, 60Hz																
15	LCD Keypad										C																		
16	UL Type										O		UL Open																
											E		UL Type 1 (conduit option unless '+DI' is present at end)																
17	EMC Filter										F		Built-in EMC Filter (only available for 460Vac up to 55kW)																
											N		No EMC filter (only option for 200Vac, 400Vac 37kW - 90kW)																
18	Reactor Type										D		Built-in dc Reactor (only available for 400Vac, 37kW - 90kW)																
											N		Non dc Reactor																
19-21	Additional Options										[blank]		No additional options if blank																
											+DI		Disconnect module																
											+FL		Flange mount																

## ATTACHMENT 3: MODEL NOMENCLATURE

## SPECIAL SEISMIC CERTIFICATION

### SP100 VFD Bypass

DOCUMENT NO.: 17101CR1.0

DIGIT:	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	-	-	-	-	-	-	-	-	-	-
SAMPLE:	L	S	L	V	0	5	5	0	S	P	1	0	0	-	4	C	E	N	D	3	-	-	-	-	-	-	-	-	-	-
DIGIT	DIGIT DESCRIPTION		CODES	DEFINITIONS																										
1-4	Product Type Prefix		LSLV																											
5-8	Power Rating		0055	5.5kW (7.5hp)																										
			0075	7.5kW (10hp)																										
			0110	11kW (15hp)																										
			0150	15kW (20hp)																										
			0185	18.5kW (25hp)																										
			0220	22kW (30hp)																										
			0300	30kW (40hp)																										
			0370	37kW (50hp)																										
			0450	45kW (60hp)																										
0550	55kW (75hp)																													
9-14	Series Name		SP100-																											
15	Input Voltage		2	200Vac (nominal), 3-Phase, 60Hz																										
			4	400Vac (nominal), 3-Phase, 60Hz																										
16	LCD Keypad		C																											
17	Enclosure		E	UL Type 1																										
18	EMC Filter		F	Built-in EMC Filter (only available for 400Vac up to 30kW)																										
			N	No EMC filter																										
19	Reactor Type		D	DC Link Reactor																										
20	Communication Options		3	3 Contactor Type																										